

Bacterial Filtration Efficiency Test (BFE) at an Increased Challenge Level GLP Report


Test Article: MicroGard II 190 g/m², Respiratory Filter
 Purchase Order: 10003754
 Laboratory Number: 530459
 Study Received Date: 28 May 2010
 Test Procedure(s): Standard Test Protocol (STP) Number: STP0009 Rev 03
 Protocol Detail Sheet (PDS) Number: 201001540 Rev 01

Summary: This procedure was performed to evaluate the bacterial filtration efficiency (BFE) at an increased challenge level of the test article. A challenge level of greater than 10⁶ colony-forming units (CFU) was delivered to each test article to determine filtration efficiency. The aerosol challenge flow rate was maintained at 30 liters per minute (LPM). This test procedure was modified from Nelson Laboratories, Inc., standard BFE procedure in order to employ a more severe challenge than would be expected in normal use. This method was adapted from ASTM F2101. All test method acceptance criteria were met.

Results:

Unit Number	Total CFU Recovered	Filtration Efficiency (%)
1	5.2 x 10 ¹	99.99959
2	2.7 x 10 ¹	99.99979
3	3.7 x 10 ¹	99.99971
4	7.2 x 10 ¹	99.99944
5	6.0 x 10 ¹	99.99953

Challenge Level: 1.3 x 10⁷ CFU
 Mean Particle Size (MPS): 3.3 μm


Study Director

Adrienne Sandall, B.S.

11 Jun 2010
Study Completion Date

Acceptance Criteria: The mean particle size (MPS) of the challenge aerosol must be maintained at $3.0 \pm 0.3 \mu\text{m}$. The average percent BFE for the reference material must be within the upper and lower control limits established for the BFE test. The BFE challenge level must be $\geq 1 \times 10^6$ CFU/test article when the flow rate is ≥ 30 LPM.

Procedure: Approximately 100 mL of soybean casein digest broth (SCDB) was inoculated with *Staphylococcus aureus*, ATCC #6538, and incubated with mild shaking for 24 ± 4 hours at $37 \pm 2^\circ\text{C}$. The culture suspension was pumped through a Chicago nebulizer using a peristaltic pump at a controlled flow rate of 30 LPM and fixed air pressure. The challenge level was adjusted to provide a consistent challenge of greater than 10^6 CFU per test article.

The droplets were generated in a glass aerosol chamber and drawn through the test article holder into AGIs in parallel. The AGIs contained 30 mL aliquots of sterile peptone water (PEPW) to collect the aerosol droplets. The challenge was delivered for a 1 minute interval and sampling through the AGIs was conducted for 2 minutes to clear the aerosol chamber. Control runs (no media in test article holder) were performed after every 5-7 test articles to determine the number of viable particles being generated in the challenge aerosol. The MPS of the challenge aerosol was determined using a six-stage Andersen sampler.

The titer of the AGI assay fluid was determined using standard plate count and/or membrane filtration techniques. All plates were incubated at $37 \pm 2^\circ\text{C}$ for 48 ± 4 hours prior to counting. The percent BFE was calculated by subtracting the counts of the test article from the average control counts and dividing by the average control counts.

Quality Assurance Statement

Compliance Statement: The test was conducted in accordance with the USFDA (21 CFR Part 58) Regulations.

Activity	Date
Study Initiation	02 Jun 2010
Audit Performed by Quality Assurance	03 Jun 2010
Audit Results Reported to Study Director	09 Jun 2010
Audit Results Reported to Management	09 Jun 2010

Scientists	Title
Todd Hillam	Section Leader
Adrienne Sandall	Study Director

Data Disposition: The raw data and final report from this study are archived at NLI or an approved off-site location.


Katie Swenson

Quality Assurance

14 Jun 2010

Date

Lab Number: 530459

	FORM TITLE:	PDS Approval Form	PDS NUMBER:	201001540
			PDS REVISION:	1

PREPARED FOR SPONSOR		LABORATORY / CONTRACTOR
CONTACT:	Helmut Scherer	Nelson Laboratories, Inc. P.O. Box 17577 SALT LAKE CITY, UT. 84117-0557 6280 SOUTH REDWOOD ROAD SALT LAKE CITY, UT. 84123-6600 Tel: 801-290-7500 Fax: 801-290-7998 Web Site: www.nelsonlabs.com
COMPANY:	CareFusion Germany 234 GmbH	
EMAIL:	helmut.scherer@CareFusion.com	
PHONE:	+49 931 4972 784	
FAX:	+49 931 4972 62784	

PROTOCOL SPECIFICATIONS			
PARENTAL DOCUMENT:	BFE at an Increased Challenge Level, STP0009, 3		
SECTION:	Aerobiology		
PDS INITIATION DATE:	13-May-2010	EXPIRATION DATE:	13-May-2012

JUSTIFICATION:

No changes to the Standard Testing Protocol.

PROTOCOL SPECIFICATIONS:


Test according to Standard Test Protocol.

Additional pages attached for protocol specifications
 No additional pages needed

The sponsor is responsible for test/control article characterization.
 This includes, but is not limited to, identity, strength, purity, and stability.

****PLEASE SIGN, DATE, & RETURN TO NELSON LABORATORIES****


SPONSOR APPROVAL:

*SIGNATURE: 

DATE: 14.05.2010

PRINT NAME: Helmut Scherer

NELSON LABS STUDY DIRECTOR APPROVAL:

SIGNATURE: 

DATE: 02 Jun 2010

PRINT NAME: Adrienne Sandall

*SIGNING THIS DOCUMENT SIGNIFIES AN ACCEPTANCE OF THE NELSON LABORATORIES TESTING TERMS AND CONDITIONS AS ATTACHED OR AS LISTED AT WWW.NELSONLABS.COM/PROTOCOLCONDITIONS.JSP

FOR OFFICE USE ONLY	See sample submission form	<input checked="" type="checkbox"/> FDA GLP	<input type="checkbox"/> NON-GLP
----------------------------	----------------------------	---	----------------------------------

©2008 by Nelson Laboratories, Inc. All rights reserved. No part of this document shall be reproduced, stored in a retrieval system, or transmitted by any means, electronic, mechanical, or otherwise, without written permission from Nelson Laboratories Inc.

FRM0206 Rev 7.1

OFFICIAL